

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1594:107 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Interlogix, Inc., 12345 SW Leveton Dr, Tualatin, OR 97062
Contact: Gene Hukkanen (503) 691-7369 FAX (503) 691-7575

DESIGN: Control unit accessories as listed below. Refer to listee's data sheet and control unit's installation instructions for additional detailed product description and operational considerations.

| | |
|---------------|-----------------------------------|
| Model 4I40-ID | 4 Input/4 Output Interface Module |
| Model SI-ID | Single Input Module |

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as control unit accessories for use with listee's separately listed compatible fire alarm control units. Model SI-ID is intended for use with Model NX-2192 Bus Interface Module. Refer to listee's Installation Instruction Manual for details.

05-25-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 23, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**